SIEMENS

Data sheet

3SE5122-0BA00



Basic switch for position switch 3SE51 Metal enclosure 56 mm wide Device connection 3x (M20x 1.5) without actuator head

SIRIUS		
Mechanical safety switches		
3SE5		
<u>3SE5000-0BA00</u>		
<u>3SE5122-0AA00</u>		
Yes		
General technical data		
Yes		
400 V		
class 3		
6 kV		
IP66/IP67		
30g / 11 ms		
0.35 mm/5g		
15 000 000		
100 000		
10 A		
В		
1 A; for a short-circuit current smaller than 400 A		
10 A; for a short-circuit current smaller than 400 A		
6 A		
mechanical		
0.05 mm		
07/01/2006		
20 N		
85.7 mm		
56 mm		
-25 +85 °C		
-40 +90 °C		
none		
mechanical		
50 60 Hz		
1		
1		

at 24 V rated value	6 A	
 at 125 V rated value 	6 A	
 at 240 V rated value 	6 A	
• at 400 V rated value	4 A	
operational current at DC-13		
 at 24 V rated value 	3 A	
 at 125 V rated value 	0.55 A	
 at 250 V rated value 	0.27 A	
 at 400 V rated value 	0.12 A	
Enclosure		
design of the housing	block, wide	
material of the enclosure	metal	
coating of the enclosure	cathodic dip coating	
design of the housing according to standard	No	
Drive Head		
design of the actuating element	Other, without, basic switch	
design of the switching function	Positive opening with appropriate positive opening actuator head	
circuit principle	slow-action contacts	
number of switching contacts safety-related	1	
cable entry type	3x (M20 x 1.5)	
Installation/ mounting/ dimensions		
mounting position	any	
fastening method	screw fixing	
Connections/ Terminals		
type of electrical connection	screw-type terminals	
type of connectable conductor cross-sections		
solid	1x (0.5 1.5 mm²), 2x (0.5 0.75 mm²)	
 finely stranded with core end processing 	1x (0.5 1.5 mm²), 2x (0.5 0.75 mm²)	
for AWG cables solid	1x (20 16), 2x (20 18)	
 for AWG cables stranded 	1x (20 16), 2x (20 18)	
design of the interface for safety-related communication	without	
Communication/ Protocol		
design of the interface	without	
Certificates/ approvals		
General Product Approval		Functional Safety/Safety of Ma- chinery
Confirma CCC		Type Examination Cer- tificate
Declaration of Conformity Test Certific	cates other	
	Certific- Confirmation	

Further information

Siemens has decided to exit the Russian market (see here). https://press.siemens.com/global/en/pressrelease/siemens-wind-down-russian-business Siemens is working on the renewal of the current EAC certificates. Please contact your local Siemens office on the status of validity of the EAC certification if you intend to import or offer to supply these products to an EAC relevant market (other than the sanctioned EAEU member states Russia or Belarus). Information on the packaging https://support.industry.siemens.com/cs/ww/en/view/109813875 Information- and Downloadcenter (Catalogs, Brochures,...) https://www.siemens.com/ic10 Industry Mall (Online ordering system) https://mall.industry.siemens.com/mall/en/en/Catalog/product?mlfb=3SE5122-0BA00 Cax online generator

ates/Test Report


http://support.automation.siemens.com/WW/CAXorder/default.aspx?lang=en&mlfb=3SE5122-0BA00


CE


EG-Konf.

Service&Support (Manuals, Certificates, Characteristics, FAQs,...) https://support.industry.siemens.com/cs/ww/en/ps/3SE5122-0BA00

Image database (product images, 2D dimension drawings, 3D models, device circuit diagrams, EPLAN macros, ...) http://www.automation.siemens.com/bilddb/cax_de.aspx?mlfb=3SE5122-0BA00&lang=en







last modified:

3/23/2022 🖸