## SEMPER Gas Discharge Tube 90 V (for series 3409)

9071.99.0748

## **Properties**

- Designed for operations
  exceeding 25 years
- GDT specification according to international standard ITU-T K.12
- Self Extinguisher GDT with holder included
- For series 3409



## Interface and material data

Housing material / pl	ating
-----------------------	-------

Brass / SUCOPLATE (R) Plating

Electrical data	
DC sparkover	90 V, +/- 20 % (@ 100 V/s)
Impulse sparkover 100 V/µs	300 V
Impulse sparkover 1000 V/ <b>µs</b>	500 V
Insulation resistance	> 10 GQ (@ 50 V)
Glow voltage	approx. 70 V (@ 10 mA)
Arc voltage	approx. 10 V (@ > 1 A)
Glow-Arc transition current	< 0.5 A
Capacitance	< 1 pF (@ 1 MHz)
DC Holdover voltage	< 150 ms (@ 52 V)
Impulse discharge current	≥ 1 operations (@ 30 kA, 8/20 µs)
	≥ 10 operations (@ 20 kA, 8/20 µs)
	≥ 400 operations (@ 500 A, 10/1000 µs)
	≥ 1000 operations (@ 100 A, 10/1000 µs or 10/7000 µs)
Alter discharge current	≥ 1 operations (@ 65 Arms, 11 cycles)
	≥ 10 operations (@ 10 Arms, 1 s)
DC current	≤ 2.5 A at 48 V
	≤ 4 A at 27 V
	≤ 6 A at 24 V
	≤ 13 A at 17 V
Turn-off time	20 sec. typically at 2.0 A and 25°C ambient temperature
	< 40 sec. typically below 1 A and 25°C ambient temperature
Recovery time	7 sec. at 25°C ambient temperature

Electrical remarks Refer to the protector datasheet for the maximum RF power







## SEMPER Gas Discharge Tube 90 V (for series 3409)

9071.99.0748

Mechanical data		
Weight	36.4 g	
Environmental data		
Operation temperature	-20 °C 85 °C	
Storage temperature	-40 °C 85 °C	
Ingress protection (IP Rating)	IP66, IP68, according to IEC 60529 (24 h of water, 1 m)	
Ingress protection (comment)	When connected to a 3409 series protector	
Additional Information		
Remarks	GDT unit for retrofit and replacement for series 3409 only	
With capsule holder	Yes	
	,	
Ordering Information Table		
Item number	Item description	

9071.99.0748

HUBER+SUHNER is certified by ISO 9001, ISO 14001, ISO 45001, IATF 16949, AS/ EN 9100 and ISO/TS 22163-IRIS. Waiver: Facts and figures herein are for information only and do not represent any warranty of any kind. DOCUMENT PIM-P1211 / Date of publication: 20.06.2024 / uncontrolled copy

84015401

